

Approval Number 2108514
Test Report: J-00392195



16th August 2021

NET INOVASYON MAKINA INS.ELEKT.KALIP.IHR.SAN.VE
TIC.AS
Saray Mahallesi Gimat Sanayi Sitesi 100.
Yil Bulvari No: 50,
Kahramankazan,
Ankara,
Turkey

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

GLASS REINFORCED PLASTICS (GRP)- COMPONENTS.

5120

'SARNIC GRP Tank Panel'. Off-white coloured, compression moulded GRP panel. For use with water up to 35°C.

APPROVAL NUMBER: 2108514

APPROVAL HOLDER: NET INOVASYON MAKINA INS.ELEKT.KALIP.IHR.SAN.VE TIC.AS

The Scheme reserves the right to review approval.

Approval 2108514 is valid between August 2021 and August 2026

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager